





POLE MOUNT HEIGHT	40'
WALL THICKNESS	.250"
POLE DIA. AT BASE	10"
POLE DIA. AT TOP	6"
ANCHOR BASE	10"-1992-T1
BOLT CIRCLE	13"-15"
ANCHOR BOLTS	1" DIA.



POLE DATA:

POLE	CIRCUIT	STATION	OFFSET	M.H.	WATT.	ARM	NOTES	FINAL
P-1	A1	13+04.42	74.86'Lt.	40'	400W	6'	FIXTURE TO CONTAIN INTERNAL HOUSE SIDE SHIELD	
P-2	A2	13+25.06	95.85'Rt.	40'	400W	6'	FIXTURE TO CONTAIN INTERNAL HOUSE SIDE SHIELD	
P-3	A1	14+49.92	87.89'Lt.	40'	400W	6'	FIXTURE TO CONTAIN INTERNAL HOUSE SIDE SHIELD	
P-4	A2	14+77.44	77.25'Rt.	40'	400W	6'	FIXTURE TO CONTAIN INTERNAL HOUSE SIDE SHIELD	
P-5	A1/A2	17+08.23	00.53'Rt.	40'	400W/400W	6'/6'		
P-6	A1/A2	19+38.68	00.37'Rt.	40'	400W/400W	6'/6'		
P-7	A1/A2	22+13.19	00.28'Rt.	40'	400W/400W	6'/6'		
P-8	A1/A2	24+34.19	00.01'Lt.	40'	400W/400W	6'/6'		
P-9	A1/A2	26+55.22	00.01'Lt.	40'	400W/400W	6'/6'		
P-10	A1/A2	28+75.46	00.11'Rt.	40'	400W/400W	6'/6'		
P-11	A1/A2	30+95.88	00.17'Rt.	40'	400W/400W	6'/6'		
P-12	A1/A2	33+10.67	00.24'Rt.	40'	400W/400W	6'/6'		
P-13	A1/A2	35+31.70	00.28'Rt.	40'	400W/400W	6'/6'		
P-14	A1/A2	37+28.10	00.76'Lt.	40'	400W/400W	6'/6'		
P-15	A3/A4	39+39.39	02.75'Lt.	40'	400W/400W	6'/6'		
P-16	A3/A4	41+45.90	02.45'Lt.	40'	400W/400W	6'/6'		
P-17	A3/A4	43+57.39	00.36'Lt.	40'	400W/400W	6'/6'		
P-18	A3/A4	45+61.40	00.17'Rt.	40'	400W/400W	6'/6'		
P-19	A3/A4	47+69.33	00.37'Rt.	40'	400W/400W	6'/6'		
P-20	A3/A4	49+69.19	00.09'Lt.	40'	400W/400W	6'/6'		

CONVENTIONAL LIGHTING DESIGN CRITERIA
 Average Initial Intensity 1.5 Foot Candles
 Avg./Min.Uniformity Ratio..... 4:1 Or Less
 Max./Min.Uniformity Ratio.....10:1 Or Less
 Wind Speed.....150 MPH

CONTACTS:

TECO PEOPLES GAS PATTY MAYES 5901 ENTERPRISE LANE FORT MYERS, FL. 33905 PH:(239) 690-5513 FAX:(239) 690-1487	COMCAST MIKE PIGOTT 26880 OLD U.S. 41 BONITA SPRINGS, FL 34134 (239) 793-9600	L.C.E.C. TRISHA DORN 4980 BAYLINE DRIVE N. FORT MYERS, FL. 33917 (239) 656-2164
EMBARQ TELEPHONE STEVE WYNKOOP PO BOX 2469 NAPLES, FL. 34106 (239) 263-6245	COLLIER COUNTY MIKE GREEN, P.E. 2885 HORSESHOE DRIVE SOUTH NAPLES, FL. 34104 (239) 252-8192	

JOB NO. F0808.03	DATE	BY	REVISIONS	DESIGNED BY R.C.F.	R.C.F.	APPROVED BY: REID C. FELLOW P.E. 61673	SEPTEMBER 17, 2009	TRANSPORTATION CONSULTANTS, INC. 13881 PLANTATION ROAD, SUITE 11 FORT MYERS, FLORIDA 33912-4339 (239) 278-3090 CERTIFICATE OF AUTHORIZATION: #27003	EVERGLADES CITY STREET LIGHTING	SHEET NO. L-3
				DRAWN BY W.L.F.	W.L.F.				POLE DATA/POLE DETAIL	